

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:27 pm

PWS ID: UTAH19046 **Name:** GLEN CANYON NRA-HALLS CROSSING

Legal Contact: NPS - GLEN CANYON NRA **Rating:** Approved
STAN AUSTIN **Rating Date:** 12/30/1899

Address: PO BOX 1507 **Activity Status:** Active
PAGE, AZ 86040

Phone Number: 435-608-6332

City Served (Area):

County: SAN JUAN COUNTY

System Type: Community **Last Inv Update:** 09/30/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/19/2008 **Total Dsgn Cap:**
Population: 120 **Surveyor:** YING YING L MACAULI **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	AUSTIN, STAN	SUPERINTEND	435-608-6254		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	90
Combined	Unknown	0	4
Commercial	Unknown	0	6
			100 Total Svc Connections

Storage

Total Storage: 300,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	300,000 GAL	Steel		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WELL #1 CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	8	135 GPM	135 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL	8	135 GPM	135 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.